

Estimates Committee 2011

Questions Taken On Notice

(14/06/2011 to 23/06/2011)

Date: 23/06/2011 Output:
Sub Output:
Subject: Shallow Power and Water infrastructure - cable discovered in shallow ground at McMinn Street development

From: Mr John Elferink to Power and Water Corporation
Power and Water Corporation

Question: **10-2**
How shallow was the Power and Water infrastructure; namely, the electrical cables discovered to be under the ground at the McMinn Street redevelopment?

Answer:
Answered On: 23/06/2011
Answer: In relation to question No 10.2, which was the depth of the cables along McMinn Street, the cables were between 300 mm and 400 mm.