

Estimates Committee 2010
Questions Taken On Notice

(11/06/2010 to 18/06/2010)

Date: 18/06/2010 Output:
Sub Output:
Subject: Emergency Generator, 70 Rocklands Drive

From: Mr David Tollner to Power and Water Corporation
Power and Water Corporation

Question: **10-4**
Question on Notice No. 10.4

Madam DEPUTY CHAIR: Can you repeat the question please, member for Fong Lim?

Mr TOLLNER: What is going on at 70 Rocklands Drive? Is it an emergency generator and how long has it been running and what is it there for?

Madam CHAIR: That is question 10.4.

Answer:
Answered On: 18/06/2010
Answer: Answer to Question 10.4

Mr MACRIDES: It is a small generator that has been in place while a transformer change out has been occurring. I think the transformer might service one of our water and sewerage pumping stations, in fact, and my understanding is the transformer change out has now occurred, and so the generator will be removed in the next few days.