

# ESTIMATES COMMITTEE

## Question Taken on Notice

**Date:** 19/06/2018  
**Subject:** Upgrade of sewerage system at Girraween Primary School  
**From:** Member for Nelson, Gerry Wood MLA  
**To:** Minister for Education, the Hon Eva Lawler MLA  
**Agency:** Department of Education

---

**Number:** 8.10

**Question:** Could you give us an update of the upgrade to the sewerage system at Girraween Primary School?

**Answer:**

The original construction of the Girraween Primary School sewerage system was limited to 50 per cent of its capacity, with a plan to expand the system as the demand increased. As the demand has now increased, a tender for the works was released and a contract recently awarded to Aqua Treat P/L to the value of \$247 775 excluding GST.

Aqua Treat P/L are a long established Darwin company who were responsible for the original design and installation of Girraween Primary School's sewerage system.

Works have commenced and are due to be completed early September 2018. During the construction works, there are no planned interruptions to the school.