

# **ESTIMATES COMMITTEE**

## **Question Taken on Notice**

**Date:** 12 June 2018

**Subject:** Truck Central Sewerage System

**From:** Mr Gerry Wood, Member for Nelson

**To:** Hon. Nicole Manison, Minister for Infrastructure, Planning and Logistics

**Agency:** Department of Infrastructure, Planning and Logistics

---

**Number:** 2.15

**Question:** Is Truck Central connected to the sewerage system or will it be operating on septic tanks?

**Answer:**

Truck Central is a Land Development Corporation project. The Land Development Corporation has provided the following:

- Truck Central is outside of Power and Water Corporation's (PWC) existing sewer network;
- In the absence of infrastructure to connect Truck Central to PWC's network, the subdivision has been designed with a dual septic and reticulated sewer system;
- The reticulated sewer system will be constructed within the subdivision to service lots when connected to PWC's network, in the medium to long term; In the short to medium term, each building development will construct a septic system to manage its waste;
- The Department will investigate the sewer servicing requirements of Wishart as part of a wider servicing strategy covering Pinelands, Wishart and Berrimah during 2018/19.