

ESTIMATES COMMITTEE

Question Taken on Notice

Date: 12 June 2018

Subject: Infrastructure Connection Berrimah North

From: Mr Gerry Wood, Member for Nelson

To: Hon. Nicole Manison, Minister for Infrastructure, Planning and Logistics

Agency: Department of Infrastructure, Planning and Logistics

Number: 2.17

Question: Is there an infrastructure connection between Berrimah North and the Northcrest development?

Answer:

- Due to the distance between the development areas, the Berrimah North infrastructure will only support developments in Berrimah North.
- In circumstances where there are multiple trunk services discharging into a treatment facility, it is a Power and Water requirement that these trunk services intersect and discharge via a single sewer main to a treatment facility. This is the case with services in this locality.
- The Berrimah North trunk sewer will intersect with the future Berrimah Farm (Northcrest) trunk sewer south of Tiger Brennan Drive, and become a new minimum DN900 trunk sewer main for the last 600 m to the Berrimah Waste Stabilisation Ponds in accordance with the Power and Water endorsed Berrimah Trunk Sewer Masterplan Concept Design Report.