

LEGISLATIVE ASSEMBLY OF THE NORTHERN TERRITORY

WRITTEN QUESTION

Dr Lim

to Minister for Infrastructure and Transport

\$30 Million Fix-Up for Alice Springs Hospital

Please detail what remediation of identified defects at the Alice Springs Hospital have been completed.

ANSWER

- Rectification of breaches in fire walls by penetrations for services, openings in cavity walls, or walls not extending fully to the structure above. All of these breaches would allow fire and smoke to infiltrate the next fire compartment of the hospital.
- Rectification of fire and smoke door installations to bring them up to compliance level.
- Rectification of associated services including below code sprinkler system, mechanical system installation and electrical network.
- These works have been completed in the areas of Day Procedure Unit and the Clinical Management Ward.

