

Estimates Committee 2003
Questions Taken On Notice

(01/10/2002 to 01/10/2004)

Date: 06/25/2003 Output:
Sub Output:
Subject: Asbestos at Ida Standley Preschool

From: Ms CARNEY to Honourable Syd STIRLING
Minister for Employment Education and Training

Question: 2-5
Has the complaint regarding asbestos in the walls at Ida Standley Preschool been remedied and, if not, will it be remedied in the work due to take place in September this year?

Answer:
Answered On: 06/27/2003
Answer: The extension work will be managed by the School Council and their consultant Zone A Architects, supervised by the Department of Infrastructure Planning & Environment (DIPE).

The asbestos contained in the area affected by the extension works will be removed by a suitably qualified contractor as part of the work to take place in September 2003. NT WorkSafe guidelines pertaining to the removal of asbestos will be enforced.

Asbestos in the remainder of the building will remain untouched and continue to be managed by DIPE as part of their overall Asset Management Strategy.